



PROJECT : **Replacement of Two (2) Units Malfunctioning 2500AMP AMP Main Low Voltage Switchgear (LVSG) Air Circuit Breaker at Central Plant NAIA Terminal 2**

DATE : **March 17, 2023**

BID BULLETIN NO. 1

1. This Bid Bulletin is hereby issued in response to the queries raised by the bidder.

Item No.	Reference	Query Raised/ Clarification Sought	Answer
1.	Asiaphil Inc.	Can we have a look of the basic specification of the Breakers?	Yes. Refer to TOR V. (Technical Specification) Page 2 of 7.
2.		Can the bidders know if there is a time frame for the installation of the Breaker?	Maximum of 1 ½ hours.
3.		What are the responsibilities of the contractors?	Refer to the Terms of Reference.
4.		What time is the last flight?	Usually the last flight is 12:30am.
5.		Would you consider the whole project or only the part of the LVSG and the allied works?	Only the amount for the installation of the Circuit Breaker/Switchgear will be considered.
6.			
7.			Clarified about the 15% price schedule, if it is possible?
8.	Equinox Enterprises	<p>One thing that was mentioned during the presentation of the project was the duration of ninety (90) calendar days period. We would like to inform you that since the COVID-19 pandemic began, there was a global shortage of the components of the circuit breakers in the market production has slowed down since then, especially in Europe, America and other neighboring countries.</p> <p>Another proof of this was from our very own experience with our project last year at Terminal 3. The ABB Vacuum Circuit Breaker took 6 months to deliver.</p> <p>In this regard, we would like to humbly request for your consideration to extend the duration of 90 calendar days from the TOR to 180 calendar days period in order to execute the project accordingly.</p>	Project duration: Ninety (90) Calendar Days.

Clarification:

- The Submission and Receipt of Bids for the above stated project is scheduled on **24 March 2023, Friday** not later than **12:00 NN** at the BAC Secretariat Office, 4th Floor, MIAA Admin. Building, NAIA Complex, Pasay City. **Late bid shall not be accepted.**
- Likewise, the Opening of Bids follows at **02:00 P.M, 24 March 2023, Friday**, at AVR, 4th Floor, MIAA Admin. Building, NAIA Complex, Pasay City.

Any instructions previously issued to the bidders inconsistent with the above provisions are deemed amended and/or superseded.

For guidance of all concerned.


BRYAN ANDERSEN Y. CO
Chairman
Bids and Awards Committee

